

iHFG Standard Components

Room Layout Sheet

RLS Room Code

echo-i


RDS Room Code

echo-i


Room Name

Echocardiography

BNL	BENCH - LAMINATE
BRCPM	BRACKET - PATIENT MONITOR
BRCB	BRACKET - SHARPS
BRCBSB	BRACKET - SUCTION BOTTLE
CAC	CABLE ACCESS CAP
CBD/FA	CUPBOARD - FULL HEIGHT, ADJUSTABLE SHELVES
CBD/WL	CUPBOARD - WALL MOUNTED, LOCKABLE
CHR/E	CHAIR - ERGONOMIC, OFFICE
CHR/P	CHAIR - PATIENT
CMP	COMPUTER
COH	COAT HOOK
COM/1	COMMUNICATION OUTLET - SINGLE
COM/2	COMMUNICATION OUTLET - DOUBLE
CPS	CURTAIN - PRIVACY SCREEN
CTPS	CURTAIN TRACK - PRIVACY SCREEN
DDG	DISPENSER - DISPOSABLE GLOVES
DHT	DISPENSER - PAPER HAND TOWEL
DK	DESK
DSA	DISPENSER - SOAP, ANTISEPTIC
EC	EMERGENCY CALL
FST	FOOTSTOOL
HWB/B	HAND WASH BASIN - TYPE 'B'
IM/USU	IMAGING - ULTRASOUND SCANNING UNIT
L/EXC	LIGHT - EXAMINATION, CEILING MOUNTED
LS/EL	LIGHT SWITCH - EXAMINATION LIGHT
MON	MONITOR
O2	OXYGEN
PC	PATIENT CALL
PCH	PATIENT CALL HANDSET
PO/1	POWER OUTLET - SINGLE
PO/1E	POWER OUTLET - EMERGENCY, SINGLE
PO/2E	POWER OUTLET - EMERGENCY, DOUBLE
S	SUCTION
SAC	STAFF ASSIST CALL
SB	SUCTION BOTTLE
SBIN	SHARPS BIN
SK4	FLOOR VINYL COVERED SKIRTING
SP	SERVICES PANEL
STAM	STOOL - ADJUSTABLE, MOBILE
T/D	TROLLEY - DRESSING
TAP/ST	TAPWARE - SENSOR TAP
TP/HS	TELEPHONE - HANDSET, STANDARD
V1	VINYL FLOORING, STANDARD SLIP RESISTANT
V6	VINYL FLOORING, NON SLIP - TEXTURED
WBC/20	WASTE BIN - CLINICAL, 20 LITRE
WBG/20	WASTE BIN - GENERAL, 20 LITRE
WPF	WALL PAINT FINISH



PLAN



ELEVATION 1

REV	DESCRIPTION	DATE	BY	REV	DESCRIPTION	DATE	BY	COMPATIBILITY
1	FIRST ISSUE	24.10.10	LL	4	GENERAL REVISION	09.09.22	BV	
2	GENERAL REVISION	30.08.11	DJ					
3	GENERAL REVISION	31.10.12	KC					



International Health Facility Guidelines at:
www.healthdesign.com.au/iHFG
Editable version of Standard Components on
Health Facility Briefing System (HFBS) at:
www.healthdesign.com.au ©TAHPI



DESIGNED	APPROVED	DATE	SCALE(S)	SHEET
BV	DB	09.09.22	1 : 50	1 OF 4
REVIT FILE NAME		PAPER DRAWING ID		ISSUE
echo-i		echo-i-1		4

This document is for advisory purpose only

iHFG Standard Components

Room Layout Sheet

RLS Room Code

echo-i


RDS Room Code

echo-i


Room Name

Echocardiography


AS	ADJUSTABLE SHELF
BH/PB	BULKHEAD - PLASTERBOARD, PAINT FINISH
BNL	BENCH - LAMINATE
C	CLOCK
CBD/FA	CUPBOARD - FULL HEIGHT, ADJUSTABLE SHELVES
CBD/UBL	CUPBOARD - UNDER BENCH, LOCKABLE
CBD/WL	CUPBOARD - WALL MOUNTED, LOCKABLE
CHR/E	CHAIR - ERGONOMIC, OFFICE
CHR/P	CHAIR - PATIENT
CMP	COMPUTER
COM/2	COMMUNICATION OUTLET - DOUBLE
CPS	CURTAIN - PRIVACY SCREEN
CTPS	CURTAIN TRACK - PRIVACY SCREEN
DFP	DOOR AND DOOR FRAME PROTECTION
DHT	DISPENSER - PAPER HAND TOWEL
DK	DESK
DSA	DISPENSER - SOAP, ANTISEPTIC
HWB/B	HAND WASH BASIN - TYPE 'B'
IM/USU	IMAGING - ULTRASOUND SCANNING UNIT
L/PT	LIGHT - PELMET TASK LIGHT
LS/DD	LIGHT SWITCH - DOWNLIGHT DIMMER
LS/P	LIGHT SWITCH - PELMET TASK LIGHT
PO/2	POWER OUTLET - DOUBLE
PO/C	POWER OUTLET - CLEANER'S
SBK	SPLASHBACK
SK4	FLOOR VINYL COVERED SKIRTING
STAM	STOOL - ADJUSTABLE, MOBILE
T/D	TROLLEY - DRESSING
TAP/ST	TAPWARE - SENSOR TAP
TP/HS	TELEPHONE - HANDSET, STANDARD
WBC/20	WASTE BIN - CLINICAL, 20 LITRE
WBG/20	WASTE BIN - GENERAL, 20 LITRE
WPF	WALL PAINT FINISH



ELEVATION 2



ELEVATION 3



ELEVATION 4

REV	DESCRIPTION	DATE	BY	REV	DESCRIPTION	DATE	BY	COMPATIBILITY
1	FIRST ISSUE	24.10.10	LL	4	GENERAL REVISION	09.09.22	BV	iHFG
2	GENERAL REVISION	30.08.11	DJ					
3	GENERAL REVISION	31.10.12	KC					



International Health Facility Guidelines at:
www.healthdesign.com.au/iHFG
 Editable version of Standard Components on
 Health Facility Briefing System (HFBS) at:
www.healthdesign.com.au ©TAHPI



DESIGNED	APPROVED	DATE	SCALE(S)	SHEET
BV	DB	09.09.22	1 : 50	2 OF 4
REVIT FILE NAME		PAPER DRAWING ID		ISSUE
echo-i		echo-i-2		4

iHFG Standard Components

Room Layout Sheet

RLS Room Code

echo-i

RDS Room Code

echo-i

Room Name

Echocardiography

GENERAL NOTES:

THIS DRAWING TO BE READ IN CONJUNCTION WITH R.D.S. (ROOM DATA SHEETS) WHICH TAKES PRECEDENCE.

ALL SERVICES INDICATED ARE INDICATIVE AND SUBJECTED TO DETAILED PROJECT SPECIFIC ENGINEERING DESIGN.

CEILING LEGEND:

	CEILING TYPE CORNICE TYPE
	HEIGHT ABOVE F.F.L.
	ACOUSTIC CEILING TILES WITH POWDERCOAT ALUMINIUM CORNICE, SHADOW LINE
	PLASTERBOARD BULKHEAD, PAINT FINISH
	GRID LINE
	TILE CEILING GRID (600X600)

ELECTRICAL LEGEND:


	L/CCD	LIGHT - COLOUR CORRECTED, DIMMABLE
	L/DR	LIGHT - DOWNLIGHT, RECESSED

MECHANICAL LEGEND:

	SUPPLY AIR GRILLE
	RETURN AIR GRILLE

FIRE SERVICES LEGEND:

	SMOKE DETECTOR
	SPRINKLER



REFLECTED CEILING PLAN

REV	DESCRIPTION	DATE	BY	REV	DESCRIPTION	DATE	BY	COMPATIBILITY				
1	FIRST ISSUE	24.10.10	LL	4	GENERAL REVISION	09.09.22	BV	iHFG				
2	GENERAL REVISION	30.08.11	DJ									
3	GENERAL REVISION	31.10.12	KC									
								DESIGNED	APPROVED	DATE	SCALE(S)	SHEET
								AM	DB	25.05.23	1 : 50	3 OF 4
								REVIT FILE NAME	PAPER DRAWING ID		ISSUE	
								echo-i	echo-i-3		4	

iHFG Standard Components

Room Layout Sheet

Room Name | Echocardiography

RLS Room Code


echo-i

RDS Room Code

dem-i



ISOMETRIC VIEW 1



ISOMETRIC VIEW 2

REV	DESCRIPTION	DATE	BY	REV	DESCRIPTION	DATE	BY	COMPATIBILITY																				
1	FIRST ISSUE	24.10.10	LL	4	GENERAL REVISION	09.09.22	BV	iHFG																				
2	GENERAL REVISION	30.08.11	DJ																									
3	GENERAL REVISION	31.10.12	KC																									
<table border="1"> <thead> <tr> <th>DESIGNED</th> <th>APPROVED</th> <th>DATE</th> <th>SCALE(S)</th> <th>SHEET</th> </tr> </thead> <tbody> <tr> <td>BV</td> <td>DB</td> <td>09.09.22</td> <td></td> <td>4 OF 4</td> </tr> <tr> <td colspan="2">REVIT FILE NAME</td> <td colspan="2">PAPER DRAWING ID</td> <td>ISSUE</td> </tr> <tr> <td colspan="2">echo-i</td> <td colspan="2">echo-i-4</td> <td>4</td> </tr> </tbody> </table>									DESIGNED	APPROVED	DATE	SCALE(S)	SHEET	BV	DB	09.09.22		4 OF 4	REVIT FILE NAME		PAPER DRAWING ID		ISSUE	echo-i		echo-i-4		4
DESIGNED	APPROVED	DATE	SCALE(S)	SHEET																								
BV	DB	09.09.22		4 OF 4																								
REVIT FILE NAME		PAPER DRAWING ID		ISSUE																								
echo-i		echo-i-4		4																								